











4월 “안전점검의 날” 개최 결과











(도시철도건축부)

안전점검의 날 개최 개요(총괄)

연번	일시	대상공사장	참여인원 (명)	지적건수 (건)	조치건수 (건)
	계	총 6개	81	10	10
1	'18.4.18	9호선3단계 918공구	9	1	1
2	'18.4.19	9호선3단계 919공구	8	2	2
3	'18.4.18	9호선3단계 920공구	19	2	2
4	'18.4.20	9호선3단계 921공구	32	2	2
5	'18.4.19	9호선3단계 922공구	4	1	1
6	'18.4.18	9호선3단계 923공구	9	2	2

점검 및 조치결과(세부내용)

연번	공사명	점검내용	조치결과	비고
1	9호선3단계 918공구			
		출입구 트랜치 부분 개구부 안전조치 미흡	안전발판 설치 완료	
2	9호선3단계 919공구			
		출입구 부분 안전조치 미흡	안전발판 보완조치 완료	
3				
		대합실 자재 정리 미흡	정리 완료	
4	9호선3단계 920공구			
		대합실 통행로 정리 정돈 미흡	정리 완료	
5	9호선3단계 920공구			
		대합실 작업구간 가설조명 미흡	가설조명 설치	

연번	공사명	점검내용	조치결과	비고
1	9호선3단계 921공구			
		대합실 자재 정리 미흡	정리 완료	
2	9호선3단계 921공구			
		그라인더 안전커버 미설치	안전커버 설치 완료	
3	9호선3단계 922공구			
		E/V앞 자재 정리 미흡	정리 완료	
4	9호선3단계 923공구			
		정거장 자재 정리 미흡	정리 완료	
5	9호선3단계 923공구			
		외부캐노피구간 자재 방치	정리정돈 및 청소 완료	

끝.